

Public Swimming Pool Inspection Report

Health District: Darke County

Name of facility <u>Holiday Inn</u>	Type visit <input checked="" type="checkbox"/> Standard <input type="checkbox"/> Re-inspection <input type="checkbox"/> Complaint <input type="checkbox"/> Epi Investigation <input type="checkbox"/> Consultation	Type pool <input checked="" type="checkbox"/> Pool <input type="checkbox"/> SPA <input type="checkbox"/> SUP	Setting <input type="checkbox"/> Wading pool <input type="checkbox"/> Zero Entry <input type="checkbox"/> Spray ground <input type="checkbox"/> School <input type="checkbox"/> Govt <input type="checkbox"/> MHP <input checked="" type="checkbox"/> Indoor <input type="checkbox"/> Outdoor <input type="checkbox"/> Camp <input type="checkbox"/> Apartment/Condo <input checked="" type="checkbox"/> Hotel/motel <input type="checkbox"/> Other _____	Special feature (SF) <input type="checkbox"/> Kiddie slide <input type="checkbox"/> Playground slide <input type="checkbox"/> Rec slide <input type="checkbox"/> Water slide <input type="checkbox"/> Fountain <input type="checkbox"/> Other _____
Address <u>1195 E. Russ Rd.</u>				
City <u>Greenville</u>				

Insp date (mm/dd/yy) <u>08-11-17</u>	Insp Time	Travel Time	ID no.	License no. <u>30</u>
Surface area (sf) <u>308</u>	Required turnover rate (min) [ie 30]	Volume (gallons) <u>8700</u>	Required flow min: (gpm) [Volume/TRate]	

43h Check if in violation of the Ohio Administrative Code 3701-31-04 (A-E); NA= Not Applicable

<input checked="" type="checkbox"/> Flow measure reading (gpm) <u>Broken</u>	<input type="checkbox"/> Max allow. filter flow: (gpm) [filter label]	<input type="checkbox"/> Max allow. flow: SF pump capacity (gpm)	<input type="checkbox"/> Max allow. flow: Jet pump capacity (gpm)
---	---	--	---

Critical violations (3701-31-04(B)(1)(a-l))

<input type="checkbox"/> (a) Outlet covers installed/secured/in compliance	<input type="checkbox"/> (d) Circulation/Disinfection system operating properly	<input type="checkbox"/> (g) Water clarity: (can see pool bottom)	<input type="checkbox"/> (j) Pool treated after RWI
<input type="checkbox"/> (b) SVRS devices functioning	<input type="checkbox"/> (e) Automatic chemical controller functioning properly	<input type="checkbox"/> (h) Natural or artificial light sufficient	<input type="checkbox"/> (k) Proper use/storage of chemicals
<input type="checkbox"/> (c) Disinfection residual as required	<input type="checkbox"/> (f) Lifeguards on duty	<input type="checkbox"/> (i) Fecal accident treated properly	<input type="checkbox"/> (l) No Electrical hazards present

Water Quality 3701-31-04 C, D

(Circle disinfectant used) Calcium Hypochlorite Sodium Hypochlorite Bromine Di-Chlor Tri-Chlor Salt **Monopersulfate (if present will interfere with DPD test kit results)	<input type="checkbox"/> (D)(6) Total Chlorine-Cl ₂ (ppm) <u>5</u>	<input type="checkbox"/> (C)(2) pH [7.2-7.8] <u>7.8</u>
	<input checked="" type="checkbox"/> (D)(6) Free Chlorine-Cl ₂ (ppm) [$\geq 1; 2$] <u>5</u>	<input type="checkbox"/> (C)(3) Alkalinity (ppm) [min 60] <u>50</u>
	<input type="checkbox"/> (D)(6) Combined-Cl ₂ / (ppm) [≤ 1] <u>0</u>	<input type="checkbox"/> (C)(6) Pool water temp [$\leq 90^{\circ}\text{F}$] <u>84^{\circ}\text{F}</u>
Secondary disinfection (circle if used)	<input type="checkbox"/> (D)(6) Total Bromine-Br ₂ (ppm) [$\geq 2; 4$]	<input type="checkbox"/> (C)(7) Spa water temp [$\leq 104^{\circ}\text{F}$]
UV light (MJoules/cm ²)	<input type="checkbox"/> (D)(6) ORP/HRR (millivolts) [≥ 650]	<input type="checkbox"/> (C)(8) Spa water replaced every 30 days
Ozone (ppm)	<input type="checkbox"/> (D)(5) Cyanuric acid (ppm) ≤ 70	
Ionization: Copper-Silver (ppm)		

Responsibilities of the Operator 3701-31-04

<input type="checkbox"/> (A) License is displayed or on file	<input type="checkbox"/> (B)(7) No domestic animals unless otherwise permitted	<input type="checkbox"/> (D)(9) Chemicals are manually added while bathers are not present
<input type="checkbox"/> (A) All construction or alterations of a pool done with approved plans	<input type="checkbox"/> (D)(1) No gas chlorine for disinfection	<input type="checkbox"/> (E)(1) Exclusion of people with obvious infectious wound or experiencing diarrhea/vomiting
<input type="checkbox"/> (B) All facilities are maintained clean, safe and sanitary condition and in good repair	<input type="checkbox"/> (D)(2) Pool is continuously disinfected by a feeding device connected to circulation system	<input type="checkbox"/> (E)(2) Safety equipment is visible and accessible
<input type="checkbox"/> (B)(2) Authorized representative available within 30 minutes	<input type="checkbox"/> (D)(3) Mixing tank for spray ground has disinfection	<input type="checkbox"/> (E)(3) Appropriate signs are posted
<input type="checkbox"/> (B)(3) Staff are knowledgeable of equipment and pool operation	<input type="checkbox"/> (D)(4) Secondary disinfection device is not adversely affecting water quality	<input type="checkbox"/> (E)(4) Lifeguards are provided and on duty as required
<input type="checkbox"/> (B)(4 & 5) Operational records maintained and on file	<input type="checkbox"/> (D)(7) Automatic chemical controller is functioning properly	
<input type="checkbox"/> (B)(6) All equipment maintained in clean, safe and sanitary condition and in good repair	<input type="checkbox"/> (D)(8) Test kit is maintained and complete	

THE ITEMS LISTED BELOW ARE IN VIOLATION OF OHIO ADMINISTRATIVE CODE CHAPTER 3701-31 AND MUST BE CORRECTED

Cite the specific rule number, explain where and what violation has occurred, and when the violation must be corrected.

(4D6) Free chlorine tested at .5ppm. Discussed minimum free residual is 1.0ppm. Please raise. PIC stated pool employee comes in at 9 to check levels prior to opening. Recommend keeping pool closed until 1.0ppm or higher.

(4C3) Alkalinity tested at 50ppm. Discussed alkalinity shall be 60ppm or higher. Please raise.

REMARKS
 See additional remarks on the attached form, HEA 5217
 Re-inspection required? Yes No;
 Compliance date: _____

(43h) Flow meter not working at time of inspection. Discussed all meters shall be maintained & functional 24 hours a day.

Sanitation/other
Gregory Kellen Phone 937-548-4146 Operator or Representative [Signature] Phone _____

Ohio Department of Health
Swimming Pool and Spa
Inspection Report
Supplement

Outdoor Indoor Wading Pool
 Swimming Pool Special Use Pool
 Spa M F Other

Page 2 of 2


Name of Establishment	HOLIDAY INN
Address	1195 E. RUSS RD. GREENVILLE

COMMENTS (continued)

(B4) Observed the total chlorine being logged as 0 ppm & combined being logged as 1 ppm on the weekly operation pool sheet in the chemical room. The formula used to calculate combined chlorine is $CC = TC - FC$. Make sure data is being logged on correct lines.

(B4) Observed only 1 entry per day on weekly operation log in chemical room. No dates or time of test was recorded for all ~~entry~~ entries recorded. Dates & time shall be recorded to prove the appropriate number of test are completed in a timely manner.

- Discussed disinfectant residual shall be tested prior to bathers entering & every 4 hours a pool is open or every 12 hours if chemical controller is working, combined chlorine & pH shall be tested prior to bathers entering & every 4 hours, total alkalinity not less than once a week. Handouts & copy of 4134 given.

OPERATOR 	SANITARIAN Megam Keeler	DATE 08-11-17
--	----------------------------	------------------