

Ohio Department of Health

# Campground Inspection Report

OAC 3701-26

- Recreation Camp
- Recreational Vehicle Park
- Combined Park-Camp
- Temporary Campground

Health District <b>Darke County</b>		Name of Campground <b>Darke Co Ag. Society</b>		Address of Campground <b>800 Swietzer St. Greenville</b>		Campground E-mail	
Owner/Operator <b>Darke Co Ag. Society</b>		Address of Owner/Operator <b>same</b>		Owner E-mail		Telephone No. <b>548-5044</b>	
Licensed Capacity <b>300</b>		License No. <b>7</b>					

Under the authority of sections 3729.01 to 3729.11 of the Revised Code, you are directed to correct the violations indicated below.

<input type="checkbox"/>	Plan Approval	<input type="checkbox"/>	Licensing	<input type="checkbox"/>	Camp Management
<input type="checkbox"/>	Campsite	<input type="checkbox"/>	Water Systems	<input type="checkbox"/>	Sewerage Systems
<input checked="" type="checkbox"/>	Dump Stations	<input type="checkbox"/>	Gray Water Systems	<input type="checkbox"/>	Hygiene Facilities
<input type="checkbox"/>	Solid Waste	<input type="checkbox"/>	Safety	<input type="checkbox"/>	Electrical

Item	Description of violation
(4L7Cii)	For dump stations equipped with a threaded faucet and hose, an ASSE 1013 reduced pressure principle backflow prevention assembly or equivalent device shall be installed prior to the threaded faucet. Both dump stations are not equipped with a backflow.
(4L4D)	Dump Stations with hoses used for flushing the station pad that shall not exceed the length necessary to reach the entire pad. North Stations hose is too long and South station does not have a hose.

Reinspection?	Reinspection Date
<input type="checkbox"/> Yes <input type="checkbox"/> No	

Based on an inspection this day, the above marked violations must be corrected by the time(s) specified in this report. Failure to comply with any specified time limit(s) may result in revocation or suspension of your Campground license.

Operator	Sanitarian <b>Megan Kaiser</b>	Date <b>8-3-14</b>
----------	-----------------------------------	-----------------------