

Public Swimming Pool Inspection Report

Health District: Darke County

Name of facility <u>Holiday Inn Express</u>	Type visit <input checked="" type="checkbox"/> Standard <input type="checkbox"/> Re-inspection <input type="checkbox"/> Complaint <input type="checkbox"/> Epi Investigation <input type="checkbox"/> Consultation	Type pool <input checked="" type="checkbox"/> Pool <input type="checkbox"/> SPA <input type="checkbox"/> SUP	Setting <input type="checkbox"/> Wading pool <input type="checkbox"/> School <input checked="" type="checkbox"/> Indoor <input type="checkbox"/> Apartment/Condo <input type="checkbox"/> Other _____	<input type="checkbox"/> Zero Entry <input type="checkbox"/> Govt <input type="checkbox"/> Outdoor <input type="checkbox"/> Camp <input type="checkbox"/> Hotel/motel	Special feature (SF) <input type="checkbox"/> Kiddie slide <input type="checkbox"/> Playground slide <input type="checkbox"/> Rec slide <input type="checkbox"/> Water slide <input type="checkbox"/> Fountain <input type="checkbox"/> Other _____
Address <u>1195 Russ Rd</u>					
City <u>Greenville</u>					

Insp date (mm/dd/yy) <u>06/30/17</u>	Insp Time	Travel Time	ID no.	License no. <u>20</u>
Surface area (sf) <u>308</u>	Required turnover rate (min) [ie 30]	<u>480</u>	Volume (gallons) <u>8700</u>	Required flow min: (gpm) [Volume/TRate] <u>19</u>

Check if in violation of the Ohio Administrative Code 3701-31-04 (A-E); NA= Not Applicable

<input checked="" type="checkbox"/> Flow measure reading (gpm) <u>Broken</u>	<input type="checkbox"/> Max allow. filter flow: (gpm) [filter label]	<input type="checkbox"/> Max allow. flow: SF pump capacity (gpm)	<input type="checkbox"/> Max allow. flow: Jet pump capacity (gpm)
---	---	--	---

Critical violations (3701-31-04(B)(1)(a-l))

<input type="checkbox"/> (a) Outlet covers installed/secured/in compliance	<input type="checkbox"/> (d) Circulation/Disinfection system operating properly	<input type="checkbox"/> (g) Water clarity: (can see pool bottom)	<input type="checkbox"/> (j) Pool treated after RWI
<input type="checkbox"/> (b) SVRS devices functioning	<input type="checkbox"/> (e) Automatic chemical controller functioning properly	<input type="checkbox"/> (h) Natural or artificial light sufficient	<input type="checkbox"/> (k) Proper use/storage of chemicals
<input type="checkbox"/> (c) Disinfection residual as required	<input type="checkbox"/> (f) Lifeguards on duty	<input type="checkbox"/> (i) Fecal accident treated properly	<input type="checkbox"/> (l) No Electrical hazards present

Water Quality 3701-31-04 C, D

(Circle disinfectant used) Calcium Hypochlorite Di-Chlor **Monopersulfate (if present will interfere with DPD test kit results)	<u>Sodium Hypochlorite</u> Tri-Chlor Bromine Salt	<input checked="" type="checkbox"/> (D)(6) Total Chlorine-Cl ₂ (ppm) <u>0.5</u>	<input type="checkbox"/> (C)(2) pH [7.2-7.8]	<u>7.6</u>
		<input checked="" type="checkbox"/> (D)(6) Free Chlorine-Cl ₂ (ppm) [≥ 1; 2] <u>0.5</u>	<input checked="" type="checkbox"/> (C)(3) Alkalinity (ppm) [min 60]	<u>30</u>
		<input type="checkbox"/> (D)(6) Combined-Cl ₂ / (ppm) [≤ 1] <u>0</u>	<input type="checkbox"/> (C)(6) Pool water temp [≤ 90°F]	<u>85</u>
Secondary disinfection (circle if used)		<input type="checkbox"/> (D)(6) Total Bromine-Br ₂ (ppm) [≥ 2; 4]	<input type="checkbox"/> (C)(7) Spa water temp [≤ 104°F]	
UV light (MJoules/cm ²)		<input type="checkbox"/> (D)(6) ORP/HRR (millivolts) [≥ 650]	<input type="checkbox"/> (C)(8) Spa water replaced every 30 days	
Ozone (ppm)		<input type="checkbox"/> (D)(5) Cyanuric acid (ppm) ≤ 70		
Ionization: Copper-Silver (ppm)				

Responsibilities of the Operator 3701-31-04

<input type="checkbox"/> (A) License is displayed or on file	<input type="checkbox"/> (B)(7) No domestic animals unless otherwise permitted	<input type="checkbox"/> (D)(9) Chemicals are manually added while bathers are not present
<input type="checkbox"/> (A) All construction or alterations of a pool done with approved plans	<input type="checkbox"/> (D)(1) No gas chlorine for disinfection	<input type="checkbox"/> (E)(1) Exclusion of people with obvious infectious wound or experiencing diarrhea/vomiting
<input type="checkbox"/> (B) All facilities are maintained clean, safe and sanitary condition and in good repair	<input type="checkbox"/> (D)(2) Pool is continuously disinfected by a feeding device connected to circulation system	<input checked="" type="checkbox"/> (E)(2) Safety equipment is visible and accessible
<input type="checkbox"/> (B)(2) Authorized representative available within 30 minutes	<input type="checkbox"/> (D)(3) Mixing tank for spray ground has disinfection	<input type="checkbox"/> (E)(3) Appropriate signs are posted
<input type="checkbox"/> (B)(3) Staff are knowledgeable of equipment and pool operation	<input type="checkbox"/> (D)(4) Secondary disinfection device is not adversely affecting water quality	<input type="checkbox"/> (E)(4) Lifeguards are provided and on duty as required
<input checked="" type="checkbox"/> (B)(4 & 5) Operational records maintained and on file	<input checked="" type="checkbox"/> (D)(7) Automatic chemical controller is functioning properly	
<input type="checkbox"/> (B)(6) All equipment maintained in clean, safe and sanitary condition and in good repair	<input type="checkbox"/> (D)(8) Test kit is maintained and complete	

THE ITEMS LISTED BELOW ARE IN VIOLATION OF OHIO ADMINISTRATIVE CODE CHAPTER 3701-31 AND MUST BE CORRECTED

Cite the specific rule number, explain where and what violation has occurred, and when the violation must be corrected.

(4c3) Alkalinity tested at 30 ppm. Discussed it shall be 60 ppm or above. Please, raise.

(4D6) Free chlorine tested at .5 ppm. Discussed it shall be a minimum of 1 ppm. Please raise & recommend closing pool until raised.

(4B6) Flow meter not working at time of inspection. Please repair. All meters shall be maintained & functional.

REMARKS
 See additional remarks on the attached form, HEA 5217
Re-inspection required? Yes No;
Compliance date: _____

Sanitarian/other
Meghan Kellew

Operator or Representative
Kira Burkhardt

Phone

page 1 of 2

Ohio Department of Health
**Swimming Pool and Spa
Inspection Report
Supplement**

Outdoor Indoor Wading Pool
 Swimming Pool Special Use Pool
 Spa M F Other

Page 2 of

Name of Establishment <u>Holiday Inn Express</u>
Address <u>1195 Russ Rd. Greenville OH 45331</u>

COMMENTS (continued)

(4B4) Observed one testing entry on weekly operation & incident report for this past Sunday through Thursday - at either 8:00am or 8:30am. No entry was logged for today on log as of 9:30 am. Discussed the disinfectant residual, combined chlorine, & pH shall be tested prior to bathers entering the pool & every 12 hours if the automatic chemical controller is working. Otherwise the levels shall be tested every 4 hours pool is open. PIC stated the pool is open from 9am-10pm. Please test and log chemicals as often as necessary to meet regulations.

(4B4) Observed the recording for Sunday through Thursday to be either 40 or 50ppm for alkalinity. No documentation on form showed what chemicals were added, if any to raise it to be 60ppm or above. Please log when chemicals are added on form.

(4Ee) Emergency phone goes to front desk. The emergency phone shall be able to call 911 or any other emergency service.

(4m) Alarm on chemical controller going off. Please repair.

OPERATOR <u>Ava Burkhardt</u>	SANITARIAN <u>Megan Keller</u>	DATE <u>6-30-17</u>
----------------------------------	-----------------------------------	------------------------