

Ohio Department of Health

Park or Camp Inspection Report

OAC 3701-26

- Recreational Vehicle Park
- Recreation Camp
- Combined Park-Camp
- Temporary Park-Camp

Health District Darke County		Address of Park or Camp 8408 Versailles SE Rd. Bradford	
Name of Park or Camp Stillwater Beach		Address of Owner/Operator Same	
Owner/Operator Robert Beck		License No. 0	
Licensed Capacity 194	Telephone No. 448-2382		

Under the authority of sections 3729.01 to 3729.11 of the Revised Code you are directed to correct the violations indicated below.

02	Plans	11	Sewage and Gray Water	19	Rules
03	Compliance with approved plan	12	Required Facilities	20	Electrical Service
04	Licensing	13	Toilet Facilities	21	Lighting
07	Density	14	Dump Stations	22	Maintenance, Rats, Mice And Noxious Plants
08	Site	15	Gray Water Facilities	23	Animals and Pets
09	Water, Sewage, Liquid Waste Systems	16	Handwashing and Shower	24	Operator Responsibility
		17	Solid Waste		
10	Water Supply	18	Safety		

Item	Description of violation
4/L ii)	Dump stations equipped with threaded faucet & hose, an ASSE 1013 reduced pressure principle backflow assembly or equivalent device shall be installed prior to the threaded faucet.
	*This may require a plumbing permit - please call Rick Bergman 937-548-4196 ext. 207 - Plumbing Inspector

Reinspection?	Reinspection Date
<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	

Based on an inspection this day, the above marked violations must be corrected by the time(s) specified in this report. Failure to comply with any specified time limit(s) may result in revocation or suspension of your Park or Camp license.

Operator <i>Robert Schmidt</i>	Sanitarian <i>Splintberg</i>	Date 5/22/18
-----------------------------------	---------------------------------	------------------------