

# Public Swimming Pool Inspection Report

Health District: **DARKE COUNTY**

Name of facility <b>Arrowhead Campground</b>	Type visit <input checked="" type="checkbox"/> Standard <input type="checkbox"/> Re-inspection <input type="checkbox"/> Complaint <input type="checkbox"/> Epi Investigation <input type="checkbox"/> Consultation	Type pool <input checked="" type="checkbox"/> Pool <input type="checkbox"/> SPA <input type="checkbox"/> SUP	Setting <input type="checkbox"/> Wading pool <input type="checkbox"/> Zero Entry <input type="checkbox"/> Spray ground <input type="checkbox"/> School <input type="checkbox"/> Govt <input type="checkbox"/> MHP <input type="checkbox"/> Indoor <input checked="" type="checkbox"/> Outdoor <input checked="" type="checkbox"/> Camp <input type="checkbox"/> Apartment/Condo <input type="checkbox"/> Hotel/motel <input type="checkbox"/> Other	Special feature (SF) <input type="checkbox"/> Kiddie slide <input type="checkbox"/> Playground slide <input type="checkbox"/> Rec slide <input type="checkbox"/> Water slide <input type="checkbox"/> Fountain <input type="checkbox"/> Other
Address <b>1361 Thomas Rd.</b>	City <b>New Paris</b>			

Insp date (mm/dd/yy) <b>06/19/2019</b>	Insp Time	Travel Time	ID no.	License no. <b>3</b>
Surface area (sf) <b>1500</b>	Required turnover rate (min) [ie 30]	<b>480</b>	Volume (gallons) <b>50,000</b>	Required flow min: (gpm) [Volume/TRate] <b>104</b>

Check if in violation of the Ohio Administrative Code 3701-31-04 (A-E); NA= Not Applicable

<input type="checkbox"/> Flow measure reading (gpm) <b>140</b>	<input type="checkbox"/> Max allow. filter flow: (gpm) [ filter label ]	<input type="checkbox"/> Max allow. flow: SF pump capacity (gpm)	<input type="checkbox"/> Max allow. flow: Jet pump capacity (gpm)
---	---	--	---

### Critical violations (3701-31-04(B)(1)(a-I))

<input type="checkbox"/> (a) Outlet covers installed/secured/in compliance	<input type="checkbox"/> (d) Circulation/Disinfection system operating properly	<input type="checkbox"/> (g) Water clarity: (can see pool bottom)	<input type="checkbox"/> (j) Pool treated after RWI
<input type="checkbox"/> (b) SVRS devices functioning	<input type="checkbox"/> (e) Automatic chemical controller functioning properly	<input type="checkbox"/> (h) Natural or artificial light sufficient	<input type="checkbox"/> (k) Proper use/storage of chemicals
<input type="checkbox"/> (c) Disinfection residual as required	<input type="checkbox"/> (f) Lifeguards on duty	<input type="checkbox"/> (i) Fecal accident treated properly	<input type="checkbox"/> (l) No Electrical hazards present

### Water Quality 3701-31-04 C, D

(Circle disinfectant used) Calcium Hypochlorite Di-Chlor **Monopersulfate (if present will interfere with DPD test kit results)	<input type="checkbox"/> (D)(6) Total Chlorine-Cl <sub>2</sub> (ppm) <b>2</b>	<input type="checkbox"/> (C)(2) pH [ 7.2-7.8 ] <b>7.3</b>
<b>Sodium Hypochlorite</b> Tri-Chlor Bromine Salt	<input type="checkbox"/> (D)(6) Free Chlorine-Cl <sub>2</sub> (ppm) [ ≥ 1; 2 ] <b>2</b>	<input type="checkbox"/> (C)(3) Alkalinity (ppm) [min 60]
	<input type="checkbox"/> (D)(6) Combined-Cl <sub>2</sub> / (ppm) [ ≤ 1 ] <b>0</b>	<input type="checkbox"/> (C)(6) Pool water temp [ ≤ 90°F ] <b>77°F</b>
Secondary disinfection (circle if used) UV light (MJoules/cm <sup>2</sup> ) Ozone (ppm) Ionization: Copper-Silver (ppm)	<input type="checkbox"/> (D)(6) Total Bromine-Br <sub>2</sub> (ppm) [ ≥ 2; 4 ]	<input type="checkbox"/> (C)(7) Spa water temp [ ≤ 104°F ]
	<input type="checkbox"/> (D)(6) ORP/HRR (millivolts) [ ≥ 650 ]	<input type="checkbox"/> (C)(8) Spa water replaced every 30 days
	<input type="checkbox"/> (D)(5) Cyanuric acid (ppm) ≤ 70	

### Responsibilities of the Operator 3701-31-04

<input type="checkbox"/> (A) License is displayed or on file	<input type="checkbox"/> (B)(7) No domestic animals unless otherwise permitted	<input type="checkbox"/> (D)(9) Chemicals are manually added while bathers are not present
<input type="checkbox"/> (A) All construction or alterations of a pool done with approved plans	<input type="checkbox"/> (D)(1) No gas chlorine for disinfection	<input type="checkbox"/> (E)(1) Exclusion of people with obvious infectious wound or experiencing diarrhea/vomiting
<input type="checkbox"/> (B) All facilities are maintained clean, safe and sanitary condition and in good repair	<input type="checkbox"/> (D)(2) Pool is continuously disinfected by a feeding device connected to circulation system	<input type="checkbox"/> (E)(2) Safety equipment is visible and accessible
<input type="checkbox"/> (B)(2) Authorized representative available within 30 minutes	<input type="checkbox"/> (D)(3) Mixing tank for spray ground has disinfection	<input type="checkbox"/> (E)(3) Appropriate signs are posted
<input type="checkbox"/> (B)(3) Staff are knowledgeable of equipment and pool operation	<input type="checkbox"/> (D)(4) Secondary disinfection device is not adversely affecting water quality	<input type="checkbox"/> (E)(4) Lifeguards are provided and on duty as required
<input type="checkbox"/> (B)(4 & 5) Operational records maintained and on file	<input type="checkbox"/> (D)(7) Automatic chemical controller is functioning properly	
<input type="checkbox"/> (B)(6) All equipment maintained in clean, safe and sanitary condition and in good repair	<input type="checkbox"/> (D)(8) Test kit is maintained and complete	

THE ITEMS LISTED BELOW ARE IN VIOLATION OF OHIO ADMINISTRATIVE CODE CHAPTER 3701-31 AND MUST BE CORRECTED

Cite the specific rule number, explain where and what violation has occurred, and when the violation must be corrected.

*Satisfactory at the time of inspection*

REMARKS <input type="checkbox"/> See additional remarks on the attached form, HEA 5217 Re-inspection required? <input type="checkbox"/> Yes <input type="checkbox"/> No; Compliance date:	Sanitarian/other 	Phone <b>548-4196</b>	Operator or Representative 	Phone <b>996-6703</b>
--	----------------------	--------------------------	--------------------------------	--------------------------