

Ohio Department of Health
Swimming Pool and Spa
Inspection Report
Supplement

Outdoor Indoor Wading Pool
 Swimming Pool Special Use Pool
 Spa M F Other

Standard - Pool Wading Pool

Page 1 of 1

Name of Establishment	Greenville City Wading Pool
Address	Greenville Park

COMMENTS (continued)

license # = 7

5/24/19

surface area = 768 turnover = 120 volume = 5760 min. flow = 48
flow reading = 50

disinfectant = sodium hypochlorite pH = 8 ppm *
total chlorine = 5 ppm alkalinity = 60 ppm
free chlorine = 5 ppm water temp = 65 F
combined chlorine = 0 ppm

pH tested to be 8.0 ppm. Discussed pH shall be
7.2 - 7.8 ppm. Please lower

OPERATOR	SANITARIAN	DATE
[Signature]	Megan Keller	5/24/19