

Ohio Department of Health

Campground Inspection Report

OAC 3701-26

- Recreation Camp
- Recreational Vehicle Park
- Combined Park-Camp
- Temporary Campground

Health District Darke County		Address of Campground 8408 Versailles SE		Campground E-mail
Name of Campground Stillwater Beach		Address of Owner/Operator Same		Owner E-mail
Owner/Operator Robert Rech		License No. 6		Telephone No. 448-2382
Licensed Capacity 194				

Under the authority of sections 3729.01 to 3729.11 of the Revised Code, you are directed to correct the violations indicated below.

<input type="checkbox"/>	Plan Approval	<input type="checkbox"/>	Licensing	<input type="checkbox"/>	Camp Management
<input type="checkbox"/>	Campsite	<input type="checkbox"/>	Water Systems	<input type="checkbox"/>	Sewerage Systems
<input checked="" type="checkbox"/>	Dump Stations	<input type="checkbox"/>	Gray Water Systems	<input type="checkbox"/>	Hygiene Facilities
<input type="checkbox"/>	Solid Waste	<input type="checkbox"/>	Safety	<input type="checkbox"/>	Electrical

Item	Description of violation
4Lii)	Dump station equipped with a threaded faucet & hose, shall have an ASSE 1013 reduced pressure principle backflow assembly or equivalent device shall be installed prior to the threaded faucet.
	Plumbing Inspector = 937 548 4196 x 207 email list of certified plumbers
	Discussed collection site next to dumpsters from drop offs. Please remove as collection occurs.

Reinspection?	Reinspection Date
<input type="checkbox"/> Yes <input type="checkbox"/> No	

Based on an inspection this day, the above marked violations must be corrected by the time(s) specified in this report. Failure to comply with any specified time limit(s) may result in revocation or suspension of your Campground license.

Operator Dutchman Schmitt	Sanitarian Megan Keller	Date 5/17/19
------------------------------	----------------------------	-----------------