



Department  
of Health



## Recommendations for Water Supply Flushing for Reopening of Buildings Under Statewide COVID-19 Transition Plan

Dear Building Occupants, Owners and Tenants,

In accordance with Ohio's statewide transition plan announced April 27, 2020, and as buildings re-open that have had little to no water usage during the Stay at Home Order due to the COVID-19 pandemic, it is important to flush water that has been stagnant in both cold- and hot-water distribution lines and fixtures. Low water usage can contribute to bacterial growth, including *Legionella* which can cause a serious type of pneumonia called Legionnaires' disease. It can also cause other water quality issues with potential health risks due to the build-up of lead and copper in stagnant water that's been collecting in older pipes and fixtures.

As buildings reopen, it is critical to drain, flush, and if necessary, based on a review of building conditions, disinfect the hot and cold-water systems to remove harmful contaminants. Devices that store water, such as drinking water fountains, water heaters, storage tanks, and any droplet or mist-forming devices such as cooling towers, humidifiers, showerheads, and certain medical and manufacturing devices and process equipment should also be flushed and disinfected in accordance with manufacturer's recommendations or industry best practices.

The Ohio Department of Health and the Ohio Environmental Protection Agency have issued the attached "Guidance for Premise Plumbing Water Service Restoration."

Please note that this guidance applies to the water systems of all types of buildings that are unoccupied or partially occupied during the COVID-19 pandemic, including but not limited to office buildings, manufacturing facilities, medical offices (e.g., physician and dentist offices, ambulatory surgery centers, outpatient centers, etc.), government facilities, and religious institutions. If you are a tenant of a building, we recommend that you share this information with the building owner, building manager, or management company and ask them to consider taking these precautions.

If you have any questions, please contact:

Ohio Department of Health  
Bureau of Environmental Health & Radiation Protection  
(614) 466-1390  
[BEH@odh.ohio.gov](mailto:BEH@odh.ohio.gov)

Ohio Environmental Protection Agency  
Division of Drinking and Ground Waters  
Emerging Contaminants Section  
(614) 644-2752

Sincerely,

Amy Acton, MD, MPH  
Director  
Ohio Department of Health

Laurie Stevenson  
Director  
Ohio Environmental Protection Agency