

Campground Inspection Report

OAC 3701-26

- Recreation Camp
- Recreational Vehicle Park
- Combined Park-Camp
- Temporary Campground

Health District Darke County		
Name of Campground Stillwater Beach	Address of Campground 8408 Versailles SE	Campground E-mail
Owner/Operator ROBERT P. ACK	Address of Owner/Operator same	Owner E-mail
Licensed Capacity 194	License No. 6	Telephone No. 448-2382

Under the authority of sections 3729.01 to 3729.11 of the Revised Code, you are directed to correct the violations indicated below.

<input type="checkbox"/>	Plan Approval	<input type="checkbox"/>	Licensing	<input type="checkbox"/>	Camp Management
<input type="checkbox"/>	Campsite	<input checked="" type="checkbox"/>	Water Systems	<input type="checkbox"/>	Sewerage Systems
<input checked="" type="checkbox"/>	Dump Stations	<input type="checkbox"/>	Gray Water Systems	<input type="checkbox"/>	Hygiene Facilities
<input checked="" type="checkbox"/>	Solid Waste	<input checked="" type="checkbox"/>	Safety	<input type="checkbox"/>	Electrical

Item	Description of violation
LD	Shorten dump station nose to length of dump pad
04-31A	Public water systems must be maintained. Hydrants around campground show signs of leakage. Please assure hydrants are shut off properly. Site D2 needs to be addressed w/ rust on hydrant, site in New lot area w/ pressure tank has been flaking + rust forming on ground
P10	Observed site 29 with a plywood lid that is deteriorating. Please have lid replaced so that it doesn't pose a potential safety risk
02	Observed lids open on dumpster. make sure they remain close to prevent any pests.
P50	Observed wooden seesaw, please so it is smooth. side was separated from base, please have repaired.
P11	Repair fence around basketball court + all 1066 sharp edges.
Reinspection? <input type="checkbox"/> Yes <input type="checkbox"/> No	Reinspection Date
P2 need to add phone sign with address + make it easily identifiable. * Please provide map of all sign-holding tanks.	

Based on an inspection this day, the above marked violations must be corrected by the time(s) specified in this report. Failure to comply with any specified time limit(s) may result in revocation or suspension of your Campground license.

Operator Deborah Schmeck	Sanitarian Ringer Nagato	Date 8/18/2020
------------------------------------	------------------------------------	--------------------------